

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7270-0992:125 Page 1 of 1

CATEGORY: Heat Detectors

LISTEE: Napco, 333 Bayview Ave., Amityville NY 11701
Contact: *Edmund Gregorian (631) 842-9400 Fax (631) 842-2726

DESIGN: Model Gem-Heat fixed temperature and rate-of-rise RF heat detector. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 135 ° F fixed temperature
15 ° F rate-of-rise

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as heat detector for use with listee's separately listed compatible fire alarm control units.

*Rev. 06-20-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 20, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager